



California Regional Water Quality Control Board, San Diego Region

April 17, 2012

Mr. Larry Tardie
All Seasons RV Park and Campground
P.O. Box 21838
Eugene, Oregon 97402

In reply refer to:
205079:ccannova

SUBJECT: REVIEW OF MONITORING REPORTS FOR ALL SEASONS RV PARK AND CAMPGROUND

Mr. Tardie:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January-June 2011 and July-December 2011 semiannual monitoring reports submitted for the All Seasons RV Park and Campground in accordance with the Monitoring and Reporting Program of Order No. 94-05.

The following violations of Discharge Specification B.1 of Order No. 94-05 were identified in the monitoring report submitted:

1. The daily maximum discharge specification for boron, established at 0.75 milligrams per liter (mg/L), was exceeded on June 10, 2011 with a reported value of 1.20 mg/L.
2. The daily maximum discharge specification for Total Suspended Solids (TSS), established at 45 milligrams per liter (mg/L), was exceeded on June 10, 2011 with a reported value of 64 mg/L.

Please take steps to implement follow-up actions necessary to ensure that the violations noted do not occur in the future. These violations subject the All Seasons RV Park and Campground to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring them to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the January-June 2012 semiannual monitoring report, which is due by July 30, 2012.

¹ Under authority of California Water Code section 13350.

In the subject line of any response, please include the requested "In refer to" information located in the heading of this letter. Please contact Ms. Catherine Cannova at (858) 627-3977 or at ccannova@waterboards.ca.gov if you have any questions on this matter.

Respectfully,

Brian D. Kelley

Brian D. Kelley, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Tech Staff Info & Use	
Reg. Measure ID	384503
Violation ID	923430
	923432